

C 48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110091

File No. 01/2023/School/75

Dated 11/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Navyug School located at Mandir Marg, New Delhi is comprised of Basement + Ground + 01 Upper Floor was earlier granted FSC by this department vide letter No. F-6/DFS/MU/2020/School/135 dated 20/03/2020. Now, the premises was re-inspected by the officer concerned of this department on 09-03-2023 in the presence of Sh. N.K. Gaur (Fire Officer) and found that the said above building have complied with the fire prevention and fire safety requirements in accordance with Rule 31 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group II "Educational Building" (Sub-Div. B-I) with effect from 11-09-2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Dated on 11/09/2023 at New Delhi by


(Gul Garg)
DIRECTOR,
Delhi Fire Service

Copy to:

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Navyug School, Mandir Marg, New Delhi.
3. Sh. N.K. Gaur, Fire Officer, Fire Department, NDMC, Patika Kendra, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Flazement shall be used as per NBC/BBL 1983.
6. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'F' [sub rule (3) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited.